

BACKFILL AND BEDDING MATERIAL SHALL BE THAWED MATERIAL WHICH IS FREE FROM FROZEN LUMPS, ICE, STUMPS, ROOTS, TRASH, CONCRETE, ASPHALT AND ANY OTHER UNACCEPTABLE MATERIAL.

COMMON STRUCTURAL BACKFILL COMPACTION TO 95% OPT. DENSITY

— IF ANY FROZEN OR DELETERIOUS
MATERIAL EXISTS IN—SITU, OVER
EXCAVATE TRENCH 12" BEFORE
BEDDING PIPE. REPLACE 12" WITH
SELECT GRAVEL AND COMPACT
TO 95% OPT. DENSITY.

BACKFILL OF TRENCH IN ADOT, CITY OF FAIRBANKS OR FNSB RIGHT OF WAY MUST COMPLY FULLY WITH THE CONDITIONS OF THE PERMITS ISSUED BY THE APPROPRIATE AGENCY.

UTILITY MAIN CENTERED IN DITCH

SEWER MAIN WITH A MIN. OF 2" URETHANE INSULATION

2, MIN' BNKA

WATER MAIN WITH A MIN.

OF 2" URETHANE INSULATION

SEPARATION

10<sup>2</sup> MIN.

MAIN CROSSING DETAIL

PLAN SCALE: NOT TO SCALE PLOT SCALE: 1=1				PLOT SCALE: 1=1
			CWH	Α
			NEW LOGOS	REVISION