

## Ravenna Park Water System

Sampling Location	Date Sampled	All results reported as Nanograms per liter(ng/L)			EPA Health Advisory Level	Result Below Health Advisory Level?
		PFOS	PFOA	Combined PFOS + PFOA		
Entry Point- 1	4/16/2020	5.0	2.2	7.2	70	Yes
Entry Point- 2	4/16/2020	5.3	2.3	7.6	70	Yes
Bulk Provider Meter 1	4/16/2020	2.9	2.3	5.2	70	Yes
Bulk Provider Meter 2	4/16/2020	5.0	3.1	8.1	70	Yes

- **PFOS** – Perfluorooctane Sulfonate
- **PFOA** – Perfluorooctanoic Acid
- **Health Advisory Level (HAL)** – To provide Americans, including the most sensitive populations, with a margin of protection from a lifetime of exposure to PFOA and PFOS from drinking water, EPA established the health advisory levels at 70 parts per trillion.
- **Ng/L** – Nanograms per liter(ng/L) which equals Parts per trillion (ppt) – One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.