



Galena
Source Water Protection
Plan

Jo Daviess County, IL
June 2024

ENGINEERING ENTERPRISES, INC.



SOURCE WATER PROTECTION PLAN

Prairie Path Water Company – Galena

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO.</u>
1.0 INTRODUCTION.....	1-1
1.1 Background	1-1
2.0 VISION STATEMENT	2-1
2.1 Policy and Commitment to Protecting Source Water	2-1
2.2 Reasons to Protect Source Water	2-1
2.3 Barriers to Protecting Source Water	2-2
2.4 Names of the Individuals Who Developed the Vision Statement	2-3
3.0 SOURCE WATER ASSESSMENT	3-1
3.1 Statement of the Importance of Source Water	3-1
3.2 List of Water Supplies that Obtain Water from the Community Water Supply ...	3-2
3.3 Delineation of all Sources of Water Used by the Community Water Supply	3-2
3.4 Report on the Quality of the Source Water for All Sources of Water.....	3-5
3.5 Report on the Quality of the Finished Water	3-7
3.6 Identification of Potential Sources of Contamination to the Source Water	3-9
3.7 Analysis of the Source Water's Susceptibility to Contamination	3-12
3.8 Explanation of the Community Water Supply's Efforts to Protect Its Source Water	3-14
4.0 SOURCE WATER PROTECTION PLAN OBJECTIVES.....	4-1
4.1 Identified Concerns	4-1
4.2 Objectives.....	4-1
5.0 ACTION PLAN	5-1
5.1 Projects, Programs, and Activities to Meet Objectives	5-1
5.2 Schedule for Implementing Projects, Programs, and Activities	5-1
5.3 Identification of Necessary Resources to Implement the Plan	5-1
5.4 Identification of Potential Problems and Obstacles in Implementing the Plan....	5-2

Tables

3-1	Water Supply Well Information.....	3-3
3-2	Source Water Quality Summary.....	3-6
3-3	Finished Water Quality Summary	3-8
3-4	Potential Contaminant Source Inventory.....	3-11
5-1	Source Water Protection Plan Schedule.....	5-3 and 5-4

Exhibits

1-1	Galena Municipal Boundary and Water Supply Wells.....	1-2
3-1	Galena Municipal Boundary and Water Supply Wells.....	3-4
3-2	Iron Concentration Trend	3-7
3-3	Map of Potential Sources of Contamination	3-11
3-4	Groundwater Susceptibility	3-13

Appendices

Appendix A.....	Source Water Protection Plan Regulations
Appendix B.....	Well Information
Appendix C	Representative Source Water Quality Analytical Reports

SECTION 1: INTRODUCTION

Prairie Path Water Company (PPWC) owns and operates the Galena Community Water System (CWS) (IL0855050) according to the rules and regulations of the State of Illinois. On July 26, 2019, the Illinois Pollution Control Board passed new and updated regulations for community water systems including Illinois Administrative Code Title 35, Subpart 604, Subpart C - Source Water Protection Plan. The purpose of this new requirement is to facilitate protection of source water quality and quantity throughout the State. It requires each community water supply that treats surface or groundwater as a primary or emergency supply of water to develop a Source Water Protection Plan (SWPP). The SWPP must contain the following minimum elements:

- a) a vision statement;
- b) a source water assessment;
- c) the objectives; and
- d) an action plan.

The specific requirements for each of the elements list above are contained in the regulation, which is included herein as Appendix A. This report is submitted to the Illinois Environmental Protection Agency (IEPA) in fulfillment of the Galena CWS's requirement under Subpart C – Source Water Protection Plan.


1.1 Background

The Galena CWS is in Guilford Township, Jo Daviess County (Exhibit 1-1). The CWS is comprised of a network of various supply, treatment, storage, distribution, and control components. The water system components are specifically designed and operated to provide safe, reliable, and affordable drinking water to the Galena CWS water customers. The existing supply consists of six wells total. Four of the six wells are shallow bedrock wells designated Thunder Bay Well 1, Thunder Bay Well 2, Eagle Ridge Well 1, and Shenandoah Well 2B. These wells draw from the dolomite and limestone Galena-Platteville group aquifers in Joe Daviess County. Shenandoah Well 2B additionally draws from the Glenwood shale and St. Peter sandstone. Likewise, Eagle Ridge Well 1 additionally draws from the Trenton and St. Peter sandstone aquifers. The other two wells are designated Resort Core Well 1B and Shenandoah Well 1B draw from the deeper sandstone and limestone Platteville-Ancell group aquifers in Jo Daviess County. The system also features three inactive wells denoted Well, Well 1, and Well 2.

The pumped water from each of Galena CWS's six wells is treated at its own individual Water Treatment Plant. Pumped water from Shenandoah 1B is treated at TP01, Shenandoah 2B is treated at TP02, Thunder Bay Well 1 is treated at TP03, Thunder Bay Well 2 is treated at TP04, Resort Core Well 1B is treated at TP05, and Eagle Ridge Well 1 is treated at TP06. Ground water from Resort Core Well 1B is treated using ion exchange technology to remove radium. The raw groundwater from all six treatment plants is treated chemically with sodium hypochlorite for bacterial disinfection and fluoridation for dental benefits. After the water is treated to meet drinking water quality standards, the finished water is then distributed to Galena's CWS's service population of 1,830 delivered through approximately 500 residential water service connections.


The effectiveness of the system depends on the availability and quality of the water used as the source of water (source water). Significant changes in source water availability or quality often require costly modifications to the water system. Therefore, the Galena CWS benefits from Source Water Protection because the program can reduce the risk of source water impairment.


Exhibit 1-1: Galena CWS Location Map



3/5/2024

 GUILFORD_TWP
  IL counties

 Galena_Wells



SECTION 2: VISION STATEMENT

This section presents the System's adherence to the requirements of Section 604.310 Vision Statement, which are:

The vision statement must include the following:

- a) the community water supply's policy and commitment to protecting source water;*
- b) an explanation of the community water supply's resources to protect source water;*
- c) an explanation of the barriers to protecting source water; and*
- d) the names of the individuals who developed the vision statement.*

2.1 Policy and Commitment to Protecting Source Water

The Prairie Path Water Company - Galena CWS policy and commitment to protect source water begins with the following vision statement:

Prairie Path Water Company is committed to Source Water Protection Programs with the purpose of ensuring the safety, integrity and sustainability of our communities' drinking water, for current and future generations to come, all in an effort to help people enjoy a better life and help communities thrive.

2.2 Resources to Protect Source Water

Prairie Path Water Company commits the following resources to protect the source water of the Galena CWS:

- Human capital and financial resources to protect our source water and to back our commitment to the preservation of safe and sustainable drinking water.
- Staff time and effort to regularly monitor the well supply, monitor changes in potential sources of contamination, and regularly coordinate with local zoning officials to identify future potential sources of contamination.
- Engaging consultants to update the existing source water protection plan to demonstrate the System's commitment to continually improving the plan with updated

information and incorporating lessons learned through experience.

- Development and continual updates to the Galena CWS Emergency Response Plan.

2.3 Barriers to Protecting Source Water

The key to ensuring clean, safe and reliable drinking water is to understand the drinking water supply from the source all the way to the consumer's tap. This knowledge includes understanding the general characteristics of the water and the land surrounding the water source, as well as mapping all the real and potential threats to the water quality. These threats can be natural, such as seasonal droughts or flooding, or created by human activity, such as agriculture, industrial practices, or recreational activities in the watershed. Threats can also arise in the treatment plant or distribution system thanks to operational breakdowns or aging infrastructure.

The multi-barrier approach takes all these threats into account and makes sure there are "barriers" in place to either eliminate them or minimize their impact. It includes selecting the best available source (e.g., lake, river, aquifer) and protecting it from contamination, using effective water treatment, and preventing water quality deterioration in the distribution system. The approach recognizes that while each individual barrier may not be able to completely remove or prevent contamination, and therefore protect public health, together the barriers work to provide greater assurance that the water will be safe to drink over the long term.

By placing integrated barriers from the source to the consumer at the tap, the Galena CWS helps protect the population it serves from the risk of contamination and waterborne disease. The System's multiple barrier approach includes:

- Source Water Protection - delineation of areas that contribute groundwater to the water supply wells, inventory of existing and future threats also referred to as potential sources of contamination, and management of activities in and around the recharge areas of wells.
- Treatment Systems – disinfection to eliminate pathogens that are responsible for waterborne diseases.

- Distribution Systems – maintaining adequate pressure within the water distribution system to prohibit inflow of non-potable water, controlling pressure during water main breaks using water system valving, conducting water main repairs quickly, and properly disinfecting water mains before they are placed back into service.
- Monitoring programs - 24-hour a day monitoring of the water system using a customized Supervisory Control and Data Acquisition (SCADA) system, frequently collecting, and analyzing water samples, security fencing, and visual inspections of operating facilities.
- Well security – PPWC wellheads are located within locked well houses and or gated off areas to protect from vandalism or intentional contamination efforts.
- Operational Response – maintaining an emergency response plan, employing certified operators with proper training and experience to operate the water system, commitment of the organization to continuous improvement, and the assistance of outside experts as needed.

2.4 Names of the Individuals Who Developed the Vision Statement

The names of the individuals who developed the Vision Statement are as follows:

- Justin Kersey, PPWC President
- Mike Miller, PPWC Director of Operations
- David Hankins, PPWC Vice President of Operations
- Steve Winter, PPWC Area Manager
- Tim Holdeman, Engineering Enterprises, Inc.
- Sydney Shaffer, Engineering Enterprises, Inc.
- Jeniece Neville, Engineering Enterprises, Inc.

SECTION 3: SOURCE WATER ASSESSMENT

This section presents the System's adherence to the requirements of Section 604.315 Source Water Assessment, which are:

- a) *The source water assessment must contain the following information:*
 - 1) *statement of the importance of the source water;*
 - 2) *a list of water supplies that obtain water from this community water supply;*
 - 3) *delineation of all sources of water used by the community water supply, including:*
 - A) *for surface water, description of the watershed, map of the watershed, and intake locations;*
 - B) *for groundwater, the well identification number, well description, well status and well depth; a description of setback zones, and a description of the aquifer for each well;*
 - 4) *a report on the quality of the source water for all sources of water delineated in subsection (a)(3), including:*
 - A) *when and where samples used to determine the quality of the source water were taken. These samples must be tested by a certified laboratory; and*
 - B) *the certified laboratory's results;*
 - 5) *a report on the quality of the finished water;*
 - 6) *identification of potential sources of contamination to the source water;*
 - 7) *analysis of the source water's susceptibility to contamination; and*
 - 8) *explanation of the community water supply's efforts to protect its source water.*

3.1 Statement of the Importance of Source Water

The importance of source water can be conveyed by the importance water plays in the communities it serves. The Galena CWS provides water to several residential and commercial sites. The Galena dolomite, Decorah limestone, Platteville limestone, Glenwood shale, and St. Peter sandstone aquifers are the primary sources of this water. The Galena CWS utilizes six (6) active community water supply wells. The system's water supply wells provide an average of 262,400 gallons per day to a population of approximately 500 people (1,830 service connections) based on the 2020 Census data. Prairie Path Water Company recognizes that no community can exist without a safe, reliable source of drinking water, and protection of that source water is of the utmost importance.

3.2 List of Water Supplies that Obtain Water from the Community Water Supply

The Galena CWS currently does not supply water to any Community Water Supplies.

3.3 Delineation of all Sources of Water Used by the Community Water Supply

The Galena CWS operates six (6) groundwater wells (Eagle Ridge Well 1, Resort Core Well 1B, Shenandoah Well 1B, Shenandoah Well 2B, Thunder Bay Well 1, Thunder Bay Well 2). A map showing the location of the water utility service area and water supply wells is shown as Exhibit 3-1. Key information about the wells is listed in Table 3-1, including information required by the SWPP regulation and additional information. Additional well information can be found in Appendix B.


The Illinois Groundwater Protection Act (IGPA) in its first phase established setback zones to prohibit the siting of potential sources of contamination within a number of feet of the wellhead. The minimum setback zone prohibits the siting of primary or secondary sources within 200 ft of the wellhead for shallow aquifers. An optional maximum setback zone of 1,000 feet is allowed to prohibit primary sources of contamination from being sited between the minimum setback and 1,000 radial feet of the well.

In the second phase, the IGPA established the delineation of a wellhead protection area (WHPA) for wells that draw from unconfined aquifers out to a 5-year time-of-travel boundary, although it is not used in this report.

Table 3-1: Water Supply Well Information

INFORMATION REQUIRED BY SWPP REGULATION							ADDITIONAL INFORMATION		
WELL ID NUMBER	WELL NAME	WELL STATUS	WELL DEPTH	CASING LENGTH	MINIMUM SETBACK	AQUIFER	ADDRESS	GPM (AVG)	YEAR DRILLED
WL11753	Thunder Bay Well 1	Active	200	42	200	Galena Dolomite, Decorah Limestone, Platteville Limestone	100 Marina Dr, Galena, IL 61036		1976
WL11754	Thunder Bay Well 2	Active	355	68	200	Galena Dolomite, Decorah Limestone, Platteville Limestone, and St. Peter Sandstone	4 Cameron Rd, Galena, IL 61036		1979
WL11756	Eagle Ridge Well 1	Active	460	137	200	Limestone, Trenton and St. Peter Sandstone aquifers	609 Territory Dr, Galena, IL 61036		1978
WL00863	Shenandoah Well 1B	Active	675	380	200	Limestone, Trenton and St. Peter Sandstone aquifers	S of the corner of N Brodrecht Rd. and Shenandoah Dr.		1976 (Gingerich records show 2005)
WL01694	Shenandoah Well 2B	Active	455	300	200	Platteville Limestone, Glenwood Shale, and St. Peter Sandstone	5 Powderhorn Gap, Galena, IL 61036		1975
WL01695	Resort Core Well 1B	Active	725	No Record	200	Platteville Limestone, Glenwood Shale, and St. Peter Sandstone	326 Territory Dr, Galena, IL 61036		1976 (Maybe 2005)
WL11755	Well	Inactive							
WL11751	Well 1	Inactive							
WL11752	Well 2	Inactive							

Exhibit 3-1: Galena CWS Boundary and Water Supply Wells



3.4 Report on The Quality of the Source Water for All Sources of Water

An analysis of the quality of groundwater from the Sandstone aquifers used by the System as its source water was conducted as part of the Source Water Assessment. Water quality data from groundwater samples from all the System's wells collected from 2013 to 2023 is presented in Table 3-2. A select number of analytical results are included in Appendix C.

The concentration of inorganic constituents in the groundwater pumped by the System's wells is summarized and compared to Class 1 Water Quality Standards for Groundwater (35 Ill. Admin. Code Part 620). Iron and cyanide are two constituents that have been recorded at levels above the Water Quality Standards. For both iron and cyanide, these exceedances were only single occurrences, and both occurred in 2015. However, per the Water Quality Standards, no official violations may occur due to naturally occurring minerals in an aquifer. All organic compounds including the Volatile Organic Compounds (VOCs) and Synthetic Organic Compounds (SOCs) were reported below the detection limits of each testing method.

Exhibit 3-2 is a graph of iron concentrations from all six of the Galena wells. The graph shows that iron concentrations generally do not waver above 2 mg/L, except for the previously mentioned high iron reading in 2015.

Table 3-2: Source Water Quality Summary

	Wells	Shenandoah Well 1B	Shenandoah Well 2B	Thunder Bay East 1	Thunder Bay East 2	Resort Core Well 1B	Eagle Ridge Well 1	Class 1 GW Qual.
Aquifer	Sand and Gravel							
	Silurian Dolomite							
	Galena-Platteville							
	St. Peter Sandstone							
	Ironton-Galesville Sandstone							
	Eau Claire Sandstone							
Inorganic Compounds	Mt. Simon Sandstone							
	Antimony (µg/L)	NR	NR	NR	NR	NR	NR	
	Arsenic (µg/L)	1 - 4.3	1 - 1.8	1 - 2.2	1	1 - 2.4	1	
	Barium (µg/L)	77 - 85	75 - 80.3	100 - 140	120 - 174	19 - 28	142 - 170	
	Beryllium (µg/L)	NR	NR	NR	NR	NR	NR	
	Boron (mg/L)	NR	NR	NR	NR	NR	NR	
	Cadmium (µg/L)	ND	ND	ND	ND	ND	ND	
	Chloride (mg/L)	2.7 - 3.8	1.2 - 3.9	10.6 - 16	1.89 - 11	3.3 - 3.4	3.9 - 7.18	
	Chromium (µg/L)	ND	ND	ND	ND	ND	ND	
	Cyanide (mg/L)	ND	ND	0.785	ND	ND	ND	
	Fluoride (mg/L)	0.397 - 1.12	0.783 - 1.06	0.14 - 0.766	0.15 - 0.856	0.708 - 0.878	0.17 - 0.901	
	Iron (mg/L)	0.4 - 0.76	0.28 - 0.78	0.03 - 10	0.056 - 1.3	0.21 - 0.31	0.01 - 0.35	
	Manganese (µg/L)	7.7 - 11	5.8 - 8.3	6.1 - 130	4.8 - 11	2.8 - 3.5	2 - 5.7	
	Mercury (µg/L)	ND	ND	ND	ND	ND	ND	
	Nickel (µg/L)	ND	53.7	ND	ND	ND	ND	
	Selenium (µg/L)	1	1 - 1.1	1	1	1	1	
	Sodium (mg/L)	3.9 - 4.8	2.53 - 5.1	6.4 - 9.2	2.02 - 6	52 - 120	3.5 - 4.5	
	Sulfate (mg/L)	28 - 35	29.5 - 31	14 - 33	17.8 - 23	46 - 86	14 - 23.4	
	Thallium (µg/L)	ND	ND	ND	ND	ND	ND	
	Total Dissolved Solids (mg/L)	310 - 400	340 - 390	360 - 410	260 - 410	370	310 - 386	
Radiologicals	ALPHA, Gross pCi/L	2.45 - 6.84	3.21 - 4.69	2.67 - 5.17	3.75 - 4.7	1.66 - 9.53	3.48	
	Radium-226 pCi/L	1.17 - 4.05	0.873 - 1.67	1.11 - 2.20	1.26 - 1.41	0.184 - 2.73	0.835 - 1.18	
	Radium-228 pCi/L	0.775 - 4.46	1.29 - 2.62	0.442 - 0.909	0.444 - 0.771	0.228 - 2.15	0.144	
	Combined Radium pCi/L	1.93 - 7.21	2.22 - 3.60	2.02 - 2.60	1.70 - 2.18	0.412 - 3.95	0.835 - 1.32	
PFAS	PFOA (ng/L)	ND	ND	ND	ND	ND	ND	
	PFOS (ng/L)	ND	ND	ND	ND	ND	ND	
	SOCs ^b (µg/L)	ND	ND	ND	ND	ND	ND	
	VOCs ^b (µg/L)	ND	ND	ND	ND	ND	ND	

Notes:
^a Results from Safe Drinking Water Information System (SDWIS) Lab Sample Numbers

EL01851-01, EL01851-02, EL01851-03, EL01851-04, EG01410-01, EF01514-01, 19G1139-01, 19G1139-02, 19G1140-01, 19G1140-02, 8104728-01, 8104728-02, 8104728-03, 8104728-04, 8042011-01, 8042011-02, 5111746-01, 5101886-01, 5101886-02, 5101886-03, 5101886-05, 5042156-01, 5042156-02, 0015221-01, 0015221-03, 0015221-05, 0015221-07, 0012721-01, 0012721-03, 4101310-01, 4101310-02, 0015221-01, 0015221-03, 0015221-05, 0015221-07, 0012721-01, 0012721-03, 19G1139-01, 19G1139-02, 19G1140-01, 19G1140-02, 5101886-04, 4101310-01, 4101310-02, 4101310-03, 4101310-04, GH02452-01, GE01288-01, GB01113-01, GB01113-02, GB01113-03, FK02433-01, FH04842-01, FE04597-01, FC01720-01, FC01720-02, EK02575-01, EG04363-01, EG02742-01, EF05637-01, EF00857-01, EA04144-01, EA04144-02, 0014366-01, 0014366-02, 0014366-03, 9010342-01, 8042047-01, 8012549-01, 8012549-02, 7012436-01, 7012436-02, 6010904-01, 5071130-01, 5042171-01, 5012196-01, 5012196-02, 4012635-01, 4012635-02, 4012635-03, 3010787-01

NR = No Record


ND = Non Detect

^b Detailed laboratory results can be found in Appendix C

Highlighted value indicates raw water concentration exceeds Class 1 Groundwater Quality Standards. In all cases, treatment is in place to reduce concentration below the standard, and routine monitoring is required.

Highlighted value indicates raw water concentration for parameter that may be approaching the Groundwater Quality Standard or may cause water quality issues. In some cases, treatment is in place to reduce concentration below the standard, and routine monitoring is recommended.

Exhibit 3-2: Iron Concentration Trend



3.5 Report on the Quality of the Finished Water

An analysis of Galena’s finished water was conducted as part of the Source Water Assessment. Table 3-3 presents a summary of the System’s finished water quality based on analytical results from 2019 to 2022. Based on the water quality sampling results shown in Table 3-3, the System’s finished water does not exceed any primary maximum contaminant levels (MCLs) with the exception of various combined radium samples which have been recorded above the MCL of 5 pCi/L from 2021 to 2023 at Shenandoah Well 1.

Shallow aquifers in much of Northeastern Illinois are experiencing elevated Per- and Polyfluoroalkyl Substances (PFAS) levels. The IEPA has initiated a statewide testing program to test for and monitor PFAS levels of 18 PFAS compounds in water supplies throughout the state but has not yet set enforceable drinking water standards for these compounds. Rather, it has set a health guidance level for six (6) PFAS compounds. The USEPA has recently promulgated MCLs for PFOS and PFOA and four (4) other PFAS compounds, although those will not take effect until 2029. The Galena System has no

detected levels of PFAS. The treatment processes applied in the Galena CWS do not remove PFAS compounds, therefore the finished water sample results are representative of PFAS compounds in the source water.

The water quality reports in the form of Consumer Confidence Report can be found on the System's website at: <https://www.myutility.us/prairiepathwater/water-safety/water-quality-reports>.

Table 3-3: Finished Water Quality Summary

			Well Effluent ^a	MCLG ^b	MCL ^b
Aquifer	Sand and Gravel				
	Silurian Dolomite				
	Galena-Platteville				
	St. Peter Sandstone				
	Ironton-Galesville Sandstone				
	Eau Claire Sandstone				
	Mt. Simon Sandstone				
IOCs	Copper	ppm	0.14 - 0.16	1.3	1.3
	Lead	ppb	3.3 - 5.2		15
	Arsenic	ppb	0 - 2		10
	Barium	ppm	0.028 - 0.17	2	2
	Iron	ppb	0.011 - 1.3		1
	Manganese	ppm	2 - 11	150	150
	Total Nitrate & Nitrite	ppm	NR	10	10
	Nitrate as N	ppb	NR	10	10
	Fluoride	ppm	0.317 - 1.12	4	4
	Sulfate	ppm	NR		
	Selenium	ppb	1.1	50	50
	Sodium	ppm	2.7 - 52		
	Zinc	ppm	0.009 - 0.075	5	5
Disinfectants	TTHMs	ppb	2.45 - 7.87		80
	HAA5	ppm	1.19		60
	Chlorine as Cl ₂	ppm	0.7 - 1.25	4	4
	TOC	n/a	NR		
Microbials	Turbidity	NTU	NR		1
	Turbidity (%<+ 0.3NTU)		NR		≤ 0.3
	Total Coliform Bacteria	#pos/mo	NR	1	
Radiologicals	Comb. Radium	ppm	0.835 - 7.21		5
	Gross ALPHA	(pCi/L)	3.75 - 7.52		15
	SOCs		NR		
	VOCs		NR		

Notes:

Results are from Galena 2019 - 2022 Water Quality Reports. NR = No Record

^a The Well Effluent column reflects the water in the distribution system. ND = Non Detect

^b MCL = Maximum Contaminant Level MCLG=Maximum Contaminant Level Goal

Highlighted value indicates raw water concentration exceeds Primary MCL for parameter. In all cases, treatment is in place to reduce concentration below the MCL, and routine monitoring is required.

Highlighted value indicates raw water concentration exceeds Secondary MCL for parameter. In some cases, treatment is in place to reduce concentration below the MCL, and routine monitoring is recommended.

Highlighted value indicates raw water concentration for parameter that may be approaching Primary or Secondary MCL or may cause water quality issues. In some cases, treatment is in place to reduce concentration below the MCL, and routine monitoring is recommended.

3.6 Identification of Potential Sources of Contamination to the Source Water

To identify all potential sources of contamination to the source water, both land use contamination and point source contamination were investigated. The proximity of the wells to shallow water bodies was also considered.

The point sources were identified using several hazardous chemical inventory databases. A list of a select number of databases used to determine potential sources of contamination to the System's wells are as follows:

- Agency Facility Inventory and Information Search System (AFIIS) (IEPA)
- Environmental Compliance and History Online (ECHO) (USEPA)
- Tier 2 Hazardous Chemical Database (IEMA Tier 2) (IEMA)
- Illinois Underground Storage Tank Database (IUST) (ISFM)
- Leaking Underground Storage Tank Database (LUST) (IEPA)
- Site Remediation Program Database (SRP) (IEPA)
- National Priority List (NPL)
- Comprehensive Environmental Response, Compensation and Liability Information System (CERCLIS)
- Resource Conservation and Recovery Act Generator List (RCRA LQG)
- Emergency Response Notification System (ERNS)
- Facility Response Plan (FRP)
- FEMA Underground Storage Tank Listing (FEMA UST)
- Clean Construction or Demolition Debris (CCDD)
- Above Ground Storage Tank (AST)

An environmental consultant, A3 Environmental, was engaged to assist in identifying potential sources of contamination within the maximum setback zone of each well. The consultant performed a search of publicly available information from environmental contamination databases belonging to federal, state, tribal, and local sources. These databases contain site specific history and details that aid in identifying if the contaminant is a threat to the source water.

In addition to these databases, the location of oil and gas pipelines and railroad lines were also evaluated. Sites within the well's 200- and 1,000-foot setback zones were considered as possible threats to groundwater quality. These locations are shown in Exhibit 3-3. A major oil pipeline crosses the edge of the 1,000-foot setback of Eagle Ridge Well 2 and crosses just outside of the 200-foot setback of Thunder Bay East Well 1. The point source potential contaminants identified are listed in Table 3-4. Along with their risk priorities. The facility at 150 Marina Drive is considered high risk because it is within the 200-foot setback and has an underground storage tank.

Exhibit 3-3: Map of Potential Sources of Contamination




Table 3-4: Potential Sources of Contamination List


Facility Name	Within 200 ft?	Well	Risk Priority	Facility Address	Facility City	Facility State	Facility Zip
Shenandoah Riding Center		Shenandoah Well 1	Low	200 N Brodrecht Rd	Galena	IL	61036
Scales Mound Fire Station 2		Eagle Ridge Well 2	Low	611 Territory Dr	Galena	IL	61036
Not Available	Yes	Thunder Bay East Well 1	High	150 Marina Dr	Galena	IL	61036

3.7 Analysis of the Source Water's Susceptibility to Contamination

The Galena CWS consists of both shallow and deep bedrock wells drawing from the St. Peter, Decorah, Glenwood, and Galena-Platteville aquifers. These aquifers are integral to many northern Illinois community water supplies. In addition, deep bedrock wells are typically less vulnerable to surface contamination than shallow bedrock wells regardless of the surface material.

Exhibit 3-4 shows the map of geologic susceptibility along with the system's wells. Shenandoah Well 1, Shenandoah Well 2, and Thunder Bay West Well 2 are in the F rating. Thunder Bay East Well 1 is in the AX rating. Eagle Ridge Resort Core Well 1 and Eagle Ridge Well 2 are in the A₁ rating. The F rating is characterized as impermeable bedrock at 20 feet or less from the surface with till or fine-grained overlay material. The AX rating is characterized as a gravel, sand, silt, and clay mixture along streams also called alluvium. The A₁ rating is characterized as permeable bedrock at 20 feet or less from the surface with varying overlay material. All the wells are shallow bedrock wells except Shenandoah Well 1 and Eagle Ridge Resort Core Well 1 which are deep bedrock wells. Eagle Ridge Well 2 has a high susceptibility to surface contamination because it is a shallow bedrock well and is in the A₁ rating. Shenandoah Well 2 and Thunder Bay West Well 2 have a low susceptibility to surface contamination even though they are shallow wells because they are in the F rating. Eagle Ridge Resort Core Well 1 has a low susceptibility to surface contamination because it is a deep bedrock well even though it is in the susceptible A₁ rating. Shenandoah Well 1 is also a deep bedrock well in addition to being in the F rating so it has a very low susceptibility to surface contamination.

Exhibit 3-4: Groundwater Susceptibility



3.8 Explanation of the Community Water Supply's Efforts to Protect its Source Water

- The Illinois Environmental Protection Act provides minimum protection zones of 200 feet for all six (6) wells: Thunder Bay Well 1, Thunder Bay Well 2, Eagle Ridge Well 1, Shenandoah Well 1B, Shenandoah Well 2B, and Resort Core Well 1B. These minimum protection zones are regulated by the Illinois EPA.
- The System's SCADA system monitors each well 24/7.
- The Galena CWS maintains the Emergency Response Plan as contingency planning documents to ensure that, through emergency preparedness, the community minimizes its risk of being without safe and adequate drinking water.
- The following regulations, which contribute to source water protection are currently active in the System:
 1. Minimum Setback Zones (200 and 400 feet, as designated by Illinois EPA) (415 ILCS 5/14.1 - 14.3)
 2. Minimum 200 feet Setback from Landscape Waste Composting and Mulching Facility (Jo Daviess Co. Code of Ordinance, 8-5B-18)
 3. Abandoned Wells (Jo Daviess Co. Code of Ordinance, Chapter 7 Water Supply, Article A - Protection of Water Supply 5-7A-8)
 4. Household Hazardous Waste Collection (Jo Daviess/Carroll Solid Waste Agency)
 5. Wells and Water Supply (Jo Daviess Co. Code of Ordinance, Chapter 7 Water Supply)
 6. Well Construction and Pump Installation (77 ILL ADMIN CODE PART 915, 920 and 925)
 7. Backflow and Cross-Connection Programs Required (Illinois Plumbing Code, 77 Ill. Adm. Code 890)
 8. Water Contamination Prevention (Jo Daviess Co. Code of Ordinances, Title 5, Chapter 3 - Nuisances)

9. Stormwater Management Program (Administered by Jo Daviess County Planning & Development Department)
10. Industrial Waste (Jo Daviess Co. Code of Ordinances Article E - General Manufacturing District and Article F - Industrial District)
11. Septic Systems (Jo Daviess Co. Code of Ordinance, 4-6-10: Site and Structure Requirements; Utilities, b> Septic Systems)
12. Subdivision Regulations (Jo Daviess Co. Code of Ordinance, Title 9 Subdivision Regulations)

SECTION 4: SOURCE WATER PROTECTION PLAN OBJECTIVES

This section presents the Galena CWS's adherence to the requirements of Section 604.320 Source Water Protection Plan Objectives, which are:

The source water protection plan must contain a list of the community water supply's objectives for protecting source water. These objectives can include meeting the requirements of any of the Sections in this Subpart, including developing a vision statement or performing a source water assessment. Objectives may also address the specific problems or issues identified in the source water assessment and should consider current and potential future issues.

4.1 Identified Concerns

The following concerns regarding the Galena CWS's source water were identified based on the source water assessment.

- Impacts of existing and potential future contamination on the Galena CWS's source water.
- Impacts of source water contamination on the Galena CWS's finished drinking water quality.
- Implications of removing existing and potential future contamination from the Galena CWS's source water to meet drinking water standards.
- Identifying and implementing effective programs and activities for protecting the Galena CWS's source water.

4.2 Objectives

Given the identified concerns, the Galena CWS developed the following SWPP objectives. These objectives provide a framework for the Galena CWS's source water protection activities. The specific activities that align with these objectives are outlined in Section 5 of this Plan.

I. Source Water Characterization / Protection Area Delineation

- A. Characterize the aquifers used by Galena CWS as the source of water supply by identifying groundwater flow patterns, estimating hydraulic properties, and analyzing groundwater quality sampling results.

II. Potential Contaminant Source and Land Use Inventories

- A. Use local, state, and federal data resources to identify the location and nature of potential sources of groundwater contamination and associated land uses within the source water protection areas of Galena CWS water supply wells.

III. Source Water Protection Management

- A. Public Engagement - Engage the community at-large and provide additional opportunities for source water protection stakeholders.
- B. Source Water Monitoring - Continue to monitor the quality of source water as needed to characterize constituents and ensure the safety of drinking water, always seeking to identify potential future threats to source water and finished water.
- C. Contingency Planning - Maintain and update existing emergency response plans, particularly as it pertains to groundwater contamination.
- D. Existing Regulatory - Leverage existing local, state, and federal regulations / programs that include source water protection components and incorporate into Galena CWS's source water protection program.
- E. New Regulatory - Consider additional programs that will contribute to protecting source water and incorporate those that are applicable into Galena CWS's source water protection program.
- F. Planning - Actively review, update, and improve all aspects of Galena CWS's Source Water Protection Plan.

SECTION 5: ACTION PLAN

This section presents the System's adherence to the requirements of Section 604.325 Action Plan, which are:

In the action plan, the community water supply must identify the actions needed to achieve the community water supply's objectives determined under Section 604.320. The action plan must include the following:

- a) descriptions of all projects, programs, and activities developed by the community water supply to meet the objectives listed in Section 604.320;*
- b) the community water supply's schedule for implementing projects, programs and activities;*
- c) an identification of the necessary resources to implement the plan; and*
- d) an identification of the potential problems with and obstacles to implementing the plan.*

5.1 Projects, Programs, and Activities to Meet Objectives

To meet its Source Water Protection Objectives, the System will continue its current initiatives (as described in Section 3.8), as well as implement the projects, programs, and activities identified below. The entire Action Plan including objectives; projects, programs, and activities; schedule; necessary resources; and potential problems is presented in Table No. 5-1.

5.2 Schedule for Implementing Projects, Programs, and Activities

The schedule for implementing the projects, programs, and activities of the System's Source Water Protection Program is presented in Table No. 5-1.

5.3 Identification of Necessary Resources to Implement the Plan

The resources necessary for implementation of the plan and the specific projects, programs, and activities requiring these resources are identified in the Action Plan presented in Table No. 5-1.

5.4 Identification of Potential Problems and Obstacles in Implementing the Plan

The potential problems and obstacles in implementing the plan and the specific projects, programs, and activities requiring these resources are identified in the Action Plan presented in Table No. 5-1.

PRAIRIE PATH WATER COMPANY - GALENA CWS SOURCE WATER PROTECTION PLAN (July 2024)

Category	Objective	Projects, Programs, and Activities	Schedule	Necessary Resources	Potential Problems
I. Source Water Characterization / Protection Area Delineation	A. Characterize the aquifers used by Galena CWS as the source of water supply by identifying groundwater flow patterns, estimating hydraulic properties, and analyzing groundwater quality sampling results.	1. Review delineated maximum setback and recharge zones refine/update as necessary.	July 2029	Staff time	Limited data available
		2. Collect static and pumping water levels along with well pumping rates; Collect well performance data during well rehabilitation and testing. Analyze these data for anomalies and trends.	Annually	Staff time	Other priorities
		3. Designate source water protection areas for each of PPWC's water supply wells. For example: minimum setback zone (200 or 400 feet), maximum setback zone (1,000 feet), or recharge areas.	Completed	N/A	N/A
II. Potential Contaminant Source and Land Use Inventories	A. Use local, state, and federal data resources to identify the location and nature of potential sources of groundwater contamination and associated land uses within the source water protection areas of Galena CWS water supply wells.	1. PPWC staff conduct visual surveys of activities within the minimum and maximum setback zones of water supply wells.	Monthly	Staff time	None
		2. Coordinate with jurisdictional authorities to monitor land use changes within the protection areas.	July 2029	Staff time	Cooperation of jurisdictions
		3. Establish program to engage local Fire Protection Authorities.	July 2029	Staff Time	Interest of jurisdictions
III. Source Water Protection Management	A. Public Engagement - Engage the community at-large and provide additional opportunities for source water protection stakeholders.	1. Public Awareness - Develop and distribute information regarding PPWC source water, including: • Newsletters • Annual Water Quality Report • Bill stuffers / Specialty mailers	Annually	Staff time	None -WQ Report must be updated for compliance
		2. Public Education - Educate community and property owners on how they can participate in PPWC's source water protection efforts.	July 2029	Staff time	Stakeholder interest
		3. Public Involvement - Consider creating local source water protection group to promote communication and collaboration on all matters pertaining to source water protection.	July 2029	Staff time	Stakeholder interest
	B. Source Water Monitoring - Continue to monitor the quality of source water as needed to characterize constituents and ensure the safety of drinking water, always seeking to identify potential future threats to source water and finished water.	1. Monitor known and emerging contaminants, including the collection of source water samples for current and emerging contaminants and the analysis of these data for anomalies and trends.	As required	Staff time	None - Must be completed for compliance
	C. Contingency Planning - Maintain and update existing emergency response plans, particularly as it pertains to groundwater contamination.	1. Update Emergency Response Plan (ERP)	Annually	Staff time	Competing priorities

PRAIRIE PATH WATER COMPANY - GALENA CWS SOURCE WATER PROTECTION PLAN page 2 (July 2024)

III. Source Water Protection Management (continued)	D. Existing Regulatory - Leverage existing local, state, and federal regulations / programs that include source water protection components and incorporate into Galena CWS's source water protection program.	1. Minimum Setback Zones (200 and 400 feet, as designated by Illinois EPA) (415 ILCS 5/14.1 - 14.3)	Ongoing	Staff time	None - State regulation
		2. Minimum 200 feet Setback from Landscape Waste Composting and Mulching Facility (Jo Daviess Co. Code of Ordinance, 8-5B-18)	Ongoing	Staff time	None - local regulation for siting facilities
		3. Abandoned Wells (Jo Daviess Co. Code of Ordinance, Chapter 7 Water Supply, Article A - Protection of Water Supply 5-7A-8)	Ongoing	Staff time	None - local regs.
		4. Household Hazardous Waste Collection (Jo Daviess/Carroll Solid Waste Agency)	Ongoing	Staff time	None - County program
		5. Wells and Water Supply (Jo Daviess Co. Code of Ordinance, Chapter 7 Water Supply)	Ongoing	Staff time	None - local regs.
		6. Well Construction and Pump Installation (77 ILL ADMIN CODE PART 915, 920 and 925)	Ongoing	Staff time	None - local regs.
		7. Backflow and Cross-Connection Programs Required (Illinois Plumbing Code, 77 Ill. Adm. Code 890)	Ongoing	Staff time	None - State regulation
		8. Water Contamination Prevention (Jo Daviess Co. Code of Ordinances, Title 5, Chapter 3 - Nuisances)	Ongoing	Staff time	None - local regs.
		9. Stormwater Management Program (Administered by Jo Daviess County Planning & Development Department)	Ongoing	Staff time	None - local regs.
		10. Industrial Waste (Jo Daviess Co. Code of Ordinances Article E - General Manufacturing District and Article F - Industrial District)	Ongoing	Staff time	None - local regs.
		11. Septic Systems (Jo Daviess Co. Code of Ordinance, 4-6-10: Site and Structure Requirements; Utilities, b, Septic Systems)	Ongoing	Staff time	None - local regs.
		12. Subdivision Regulations (Jo Daviess Co. Code of Ordinance, Title 9 Subdivision Regulations)	Ongoing	Staff time	None - local regs.
	E. New Regulatory - Consider additional programs that will contribute to protecting source water and incorporate those that are applicable into Galena CWS's source water protection program.	1. Overlay Ordinance establishing a 1,000-foot maximum setback zone.	July 2029	Staff time	Cooperation of local jurisdiction
		2. Signage at wells and water treatment facilities	July 2029	Staff time, cost of signs	None
		3. Land acquisition / Conservation easements	July 2029	Staff time, funding	Availability of land
	F. Planning - Actively review, update, and improve all aspects of Galena CWS's Source Water Protection Plan.	1. Participation in the Local Emergency Planning Committee (LEPC) or other local water resources planning agencies.	July 2029	Staff time	Competing priorities
		2. Support County Water Sustainability efforts (if applicable).	July 2029	Staff time	Existence of such programs
		3. Periodic review and updating of the Source Water Protection Plan Vision statement, Source Water Assessment, Objectives, and Action Plan with input from external stakeholders.	July 2029	Staff time / Consultant	None -required for compliance

APPENDIX A

Illinois Administrative Code Title 35, Subpart 604, Subpart C - Source Water Protection Plan

TITLE 35: ENVIRONMENTAL PROTECTION
SUBTITLE F: PUBLIC WATER SUPPLIES
CHAPTER I: POLLUTION CONTROL BOARD

PART 604
DESIGN, OPERATION AND MAINTENANCE CRITERIA

SUBPART C: SOURCE WATER PROTECTION PLAN

Section 604.300 Purpose

The purpose of the following requirements is to facilitate protection of source water quality and quantity.

Section 604.305 Source Water Protection Plan Requirement and Contents

Each community water supply that treats surface or groundwater as a primary or emergency supply of water must develop a source water protection plan that contains the following minimum elements:

- a) a vision statement as set forth in Section 604.310;
- b) a source water assessment as set forth in Section 604.315;
- c) the objectives set forth in Section 604.320; and
- d) an action plan as set forth in Section 604.325.

Section 604.310 Vision Statement

The vision statement must include the following:

- a) the community water supply's policy and commitment to protecting source water;
- b) an explanation of the community water supply's resources to protect source water;
- c) an explanation of the barriers to protecting source water; and
- d) the names of the individuals who developed the vision statement.

Section 604.315 Source Water Assessment

- a) The source water assessment must contain the following information:
 - 1) statement of the importance of the source water;

- 2) a list of water supplies that obtain water from this community water supply;
 - 3) delineation of all sources of water used by the community water supply, including:
 - A) for surface water, description of the watershed, map of the watershed, and intake locations;
 - B) for groundwater, the well identification number, well description, well status and well depth; a description of setback zones, and a description of the aquifer for each well;
 - 4) a report on the quality of the source water for all sources of water delineated in subsection (a)(3), including:
 - A) when and where samples used to determine the quality of the source water were taken. These samples must be tested by a certified laboratory; and
 - B) the certified laboratory's results;
 - 5) a report on the quality of the finished water;
 - 6) identification of potential sources of contamination to the source water;
 - 7) analysis of the source water's susceptibility to contamination; and
 - 8) explanation of the community water supply's efforts to protect its source water.
- b) Upon request, the Agency will provide technical assistance to a community water supply in conducting the source water assessment.
 - b) A community water supply may use a Source Water Assessment Program Fact Sheet prepared by the Agency to fulfill the requirements of this Section.

Section 604.320 Source Water Protection Plan Objectives

The source water protection plan must contain a list of the community water supply's objectives for protecting source water. These objectives can include meeting the requirements of any of the Sections in this Subpart, including developing a vision statement or performing a source water

assessment. Objectives may also address the specific problems or issues identified in the source water assessment and should consider current and potential future issues.

Section 604.325 Action Plan

In the action plan, the community water supply must identify the actions needed to achieve the community water supply's objectives determined under Section 604.320. The action plan must include the following:

- a) descriptions of all projects, programs, and activities developed by the community water supply to meet the objectives listed in Section 604.320;
- c) the community water supply's schedule for implementing projects, programs and activities;
- c) an identification of the necessary resources to implement the plan; and
- d) an identification of the potential problems with and obstacles to implementing the plan.

Section 604.330 Submission

- a) A community water supply that first commenced construction after July 26, 2019, must develop and submit a source water protection plan simultaneously with the construction permit application.
- b) A community water supply in existence as of July 26, 2019, must develop and submit to the Agency for approval a source water protection plan within the following time frame after July 26, 2019:
 - 1) within 3 years, for a community water supply serving a population greater than 50,000 persons;
 - 2) within 4 years, for a community water supply serving a population of greater than 3,000 but less than or equal to 49,999 persons; or
 - 3) within 5 years, for a community water supply serving a population of less than or equal to 2,999 persons.
- d) An existing community water supply that anticipates using a new source of water for its supply must develop and submit a revised source water protection plan simultaneously with the construction permit application.

Section 604.335 Agency Approval

The Agency, not later than 45 days after the receipt of the source water protection plan, will either approve or disapprove the plan. If the Agency takes no action within the 45 days, the community water supply may deem the plan approved. A community water supply may waive the requirement that the Agency take an action within the 45 days by so advising the Agency in writing.

Section 604.340 Evaluation and Revision

The community water supply must review, and revise as necessary, its source water protection plan no less frequently than every five years. If the community water supply revises its source water protection plan, it must submit the plan to the Agency for approval under Section 604.335.

APPENDIX B

Well Information

**Illinois Department of Public Health
WATER WELL CONSTRUCTION REPORT**

Date 8/5/05

TYPE OR PRESS FIRMLY WITH BLACK INK PEN. COMPLETE WITHIN 30 DAYS OF WELL COMPLETION AND SEND TO THE APPROPRIATE HEALTH DEPARTMENT.

1. Type of Well a. Driven Well Casing diam. _____ in. Depth _____ ft.
 b. Bored Well Buried Slab ☐ Yes ☐ No
 Hole Diameter _____ in. to _____ ft.; _____ in. to _____ ft.; _____ in. to _____ ft.
 c. Drilled Well PVC casing Formation packer set at depth of _____ ft.
 Hole Diameter _____ in. to _____ ft. _____ in. to _____ ft. _____ in. to _____ ft.

Type of Grout	# of Bags	Grout Weight	From (ft.)	To (ft.)	Tremie Depth (ft.)

- d. Drilled Well Steel Casing - - Mechanically Driven ☐ Yes ☒ No
 Hole Diameter 18 in. to 21 ft. 13 in. to 380 ft. 7/8 in. to 642 ft.

Type of Grout	# of Bags	Grout Weight	From (ft.)	To (ft.)	Tremie Depth (ft.)
Cement	180		0	380	N/A

X Sandstone

- e. Well finished within ☐ Unconsolidated Materials ☐ Bedrock

- f. Kind of Gravel Sand Pack Grain Size/Supplier # From (ft.) To (ft.)

2. Well Use ☒ Domestic ☐ Irrigation ☐ Commercial ☐ Livestock
☐ Monitoring ☐ Other

3. Date Well Completed 8/2/05 Well Disinfected ☒ Yes ☐ No

Driller's estimated well yield 250 gpm

4. Date Permanent Pump Installed 8-24-2005

5. Pump Capacity 200 gpm Set at (depth) _____ ft.

6. Pitless Adapter Model and Manufacturer MONITOR 8"

7. Well Cap Type and Manufacturer _____

8. Pressure Tank Working Cycle _____ gals. Captive Air ☐ Yes ☐ No

9. Pump System Disinfected ☒ Yes ☐ No

10. Name of Pump Company PEERLESS SERVICE CO.

11. Pump Installer _____ License # _____

12. _____ License # _____

Licensed Pump Contractor Signature

Illinois Department of Public Health
 Division of Environmental Health
 525 W. Jefferson St.
 Springfield, IL 62761

DO NOT write on these lines

IMPORTANT NOTICE: This state agency is requesting disclosure of information that is necessary to accomplish the statutory purpose as outlined under Public Act 85-0863. **DISCLOSURE OF THIS INFORMATION IS MANDATORY.** This form has been approved by the Forms Management Center.

GEOLOGICAL AND WATER SURVEY WELL RECORD

13. Property Owner Galena Utilites Well # Shenandoah 1B
 14. Driller Klint Gingerich License # 092-008051
 15. Name of Drilling Co. Gingerich Well
 16. Permit No. 2434-FY2005 Date Issued 7/12/05
 17. Date Drilling Started 7-26-2005 * 126 N. Brodrecht Rd
 18. Well SITE address West Wachter Road Galena
 19. Township Name Guilford Land ID # _____
 20. Subdivision Name _____ Lot # _____
 21. Location a. County Jo Daviess

- b. Township 28N Range 2E Section 19

- c. _____ Quarter _____ Quarter SW Quarter

- d. Coordinates _____ Site Elevation _____ ft. (msl)

22. Casings, Liners* and Screen Information

Diam. (in.)	Material	Joint	Slot Size	From (ft.)	To (ft.)
8"	Steel	Weld			

(*)

(List reason for liner, type of upper and lower seals installed)

23. Water from sandstone at a depth of 380 ft. to 620 ft.

- a. Static water level 236 ft. below casing which is 18 in. above ground

- b. Pumping level is 331 ft. pumping 150 gpm after pumping for 12 hours

24. Earth Materials Passed Through

From (ft.)	To (ft.)
0	21
21	270
270	274
274	340
340	348
348	433
433	580
580	619
619	621
621	642

Limestone
 (If dry hole, fill out log and indicate how hole was sealed.)

25. Licensed Water Well Contractor Signature

092-008051

License Number

SEE REVERSE SIDE FOR ADDITIONAL INFORMATION)

"YOUR WELL BEING OUR BUSINESS"

1331 Highway 1
Kalona, Iowa 52247-9517

Gingerich

Emery Gingerich
Klint Gingerich
Corwin Gingerich

WELL & PUMP SERVICE, LLC

WELL DRILLING & REPAIR ■ PIPELINE TRENCHING

319-656-2664

OWNER GALENA UTILITIES DATE DRILLED 8/1/05

ADDRESS 8" SHENANDOAH #1 WELL GALENA DEPTH OF WELL 642

SIZE TOP 8 BOTTOM 8 CASED TO 380 WITH 8 TYPE STEEL

LINED WITH _____ FROM _____ TO _____ AND WITH _____ FROM _____ TO _____

FEET OF SAND _____ FROM _____ TO _____ DEPTH TO ROCK 21

MAIN SUPPLY FROM 380 TO 620 AND FROM _____ TO _____

MFG OF SCREEN _____ TYPE OF MATERIAL _____

SLOT OPENING _____ TOTAL LENGTH _____ FEET EXPOSED _____

STATIC WATER LEVEL 235 PUMPING LEVEL _____ AT _____ GPM

DRILLING FOREMAN KLINT GINGERICH

	Top	Bottom
overburden	0	26
Galena dolomite	26	104
Decorah limestone	104	151
Platteville limestone	151	200
Total Depth		200
Casing: 12" A53-B T & C 45#/FT from 0' to 28'		
8" A53-B T & C 25#/FT from 0' to 42'		
Size hole below casing: 8"		
Water from limestone at 30' to 200'.		
Static level 23' below casing top which is 1' above GL		
Pumping level 125' when pumping at 75 gpm for 4 hours		
Permanent pump installed at 180'		
Remarks: Sub-division water supply		
Driller's Log filed		
Owner Address: Box 1000 Galena, IL		
Add'l loc. info: Subdivision: Thunder Bay #1		
Location source: Location from permit		

Permit Date: September 15, 1976 Permit #: 52202

COMPANY Miles, Edwin

FARM Galena Territory

DATE DRILLED May 20, 1977

ELEVATION 0

LOCATION 1400'N line, 1200'E line of NE

LATITUDE 42.411957

COUNTY JoDaviess


NO. 1

COUNTY NO. 20864

LONGITUDE -90.326392

API 120852086400

19 - 28N - 2E



Municipal Water Supply	Top	Bottom
gravel & clay	0	17
Galena limestone	17	130
Oil rock (Guttenberg)	130	140
Platteville limestone	140	335
Glennwood	335	354
St. Peter sandstone	354	455
Total Depth		455
Casing: 12" from 0' to 17'		
8" ASTM 29.35#/FT from 17' to 300'		
Grout: NEAT CEMENT from 0 to 0.		
Pumping level 0' when pumping at 170 gpm for 0 hours		
Remarks: deepening of existing well		
Owner Address: Galena Territory - Utilities ,		
Address of well: Powderhorn Gap		
Add'l loc. info: FALSE		
The Galena Territory		
Location source: Location from the driller		

Permit Date: January 15, 1993

Permit #: E930952

COMPANY Lyons, Larry

FARM Shenandoah

DATE DRILLED May 31, 1993

NO. 2B

ELEVATION 897GL

COUNTY NO. 21828

LOCATION 2200'S 2550'W NE/c


LATITUDE 42.380502

LONGITUDE -90.310217

COUNTY JoDaviess

API 120852182800

32 - 28N - 2E



	Top	Bottom
soil & clay	0	7
yellow lime & dolomite	7	95
gray lime & dolomite	95	210
Decorah limestone	210	244
Platteville limestone	244	304
St. Peter sandstone	304	355
Total Depth		355
Casing: 12" STL 44 LBS PER FT from 1' to 10'		
8" PLAIN END STL 25#/FT from 1' to 68'		
Size hole below casing: 8"		
Water from St. Peter at 70' to 355'.		
Static level 70' below casing top which is 1' above GL		
Pumping level 168' when pumping at 275 gpm for 24 hours		
Permanent pump installed at 260'		
Remarks: Thunder Bay West Well #1		
Driller's Log filed		
Owner Address: Box 1000 Thunder Bay West Well #1 Galena, IL		
Location source: Platbook verified		

Permit Date: March 29, 1978

Permit #: 72407

COMPANY Miles, Randolph S.

FARM Galena Territory TB

DATE DRILLED October 15, 1978

NO. 3

ELEVATION 0

COUNTY NO. 21021

LOCATION 1930'S line, 1550'W line of section


LATITUDE 42.421068

LONGITUDE -90.336147

COUNTY JoDaviess

API 120852102100

18 - 28N - 2E



APPENDIX C

Representative Source Water Quality Analytical Lab Reports

Galena Water System

Sampling Location	Date Sampled	All results reported as Nanograms per liter(ng/L)				Result Below Health Advisory Level?
		PFOS	PFOA	Combined PFOS + PFOA	EPA Health Advisory Level	
Entry Point Well S1B	6/22/2020	ND	ND	ND	70	Y
Entry Point Well S2B	6/22/2020	ND	ND	ND	70	Y
Entry Point Well TB1	6/22/2020	ND	ND	ND	70	Y
Entry Point Well TB2	6/22/2020	ND	ND	ND	70	Y
Entry Point Well R1B	6/22/2020	ND	ND	ND	70	Y
Entry Point Well E1	6/22/2020	ND	ND	ND	70	Y

- **PFOS** – Perfluorooctane Sulfonate
- **PFOA** – Perfluorooctanoic Acid
- **Health Advisory Level (HAL)** – To provide Americans, including the most sensitive populations, with a margin of protection from a lifetime of exposure to PFOA and PFOS from drinking water, EPA established the health advisory levels at 70 parts per trillion.
- **Ng/L** – Nanograms per liter(ng/L) which equals Parts per trillion (ppt) – One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
- **ND (No Detect)** - Laboratory analysis indicates that the constituent is not present. 2.0 ng/L is the minimum level the lab is reporting a detection for these parameters. The ND (No Detect) represented in the table is indicating there was no detection.

Drinking Water Branch

Chem/Rad Sample Results

[Return
Links](#)

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water
Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	EL01848-01	Collection Date :	12-07-2021

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1005	ARSENIC	200.8	Y	MRL	1 UG/L		01-01-2020	12-31-2022
1010	BARIUM	200.8			0	120 UG/L	01-01-2020	12-31-2022
1015	CADMIUM	200.8	Y	MRL	1 UG/L		01-01-2020	12-31-2022
1017	CHLORIDE	300.0			0	3.1 MG/L	01-01-2020	12-31-2022
1020	CHROMIUM	200.8	Y	MRL	4 UG/L		01-01-2020	12-31-2022
1024	CYANIDE	335.4	Y	MRL	0.2 MG/L		01-01-2020	12-31-2028
1025	FLUORIDE	4500F-C			0	0.43 MG/L	01-01-2020	12-31-2022
1028	IRON	200.7			0	0.34 MG/L	01-01-2020	12-31-2022
1031	MAGNESIUM	200.7			0	36 MG/L		
1032	MANGANESE	200.8			0	5 UG/L	01-01-2020	12-31-2022
1035	MERCURY	200.8	Y	MRL	0.2 UG/L		01-01-2020	12-31-2022
1036	NICKEL	200.8	Y	MRL	5 UG/L		01-01-2020	12-31-2022
1045	SELENIUM	200.8			0	1.2 UG/L	01-01-2020	12-31-2022
1052	SODIUM	200.7			0	4.4 MG/L	01-01-2020	12-31-2022
1055	SULFATE	300.0			0	17 MG/L	01-01-2020	12-31-2022
1074	ANTIMONY, TOTAL	200.8	Y	MRL	3 UG/L		01-01-2020	12-31-2022
1075	BERYLLIUM, TOTAL	200.8	Y	MRL	1 UG/L		01-01-2020	12-31-2022
1085	THALLIUM, TOTAL	200.8	Y	MRL	1 UG/L		01-01-2020	12-31-2022
1095	ZINC	200.8			0	19 UG/L	01-01-2020	12-31-2022
1915	HARDNESS, TOTAL (AS CaCO3)	2340B			0	290 MG/L	01-01-2020	12-31-2022
1919	CALCIUM	200.7			0	56 MG/L	01-01-2020	12-31-2022
1927	ALKALINITY, TOTAL	2320B			0	270 MG/L	01-01-2020	12-31-2022
1930	TDS	2540C			0	360 MG/L	01-01-2020	12-31-2022

Total Number of Records Fetched = 23

Drinking Water Branch

Chem/Rad Sample Results

[Return
Links](#)

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water
Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	5102164-01	Collection Date :	10-13-2015

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1005	ARSENIC	200.8	Y	MRL	1 UG/L		01-01-2014	12-31-2016
1010	BARIUM	200.8			0	88 UG/L	01-01-2014	12-31-2016
1015	CADMIUM	200.8	Y	MRL	1 UG/L		01-01-2014	12-31-2016
1020	CHROMIUM	200.8	Y	MRL	4 UG/L		01-01-2014	12-31-2016
1024	CYANIDE	4500CN-C	Y	MRL	0.2 MG/L		01-01-2011	12-31-2019
1025	FLUORIDE	4500F-C			0	1.05 MG/L	01-01-2014	12-31-2016
1028	IRON	200.7			0	0.79 MG/L	01-01-2014	12-31-2016
1032	MANGANESE	200.8			0	7.6 UG/L	01-01-2014	12-31-2016
1035	MERCURY	200.8	Y	MRL	0.2 UG/L		01-01-2014	12-31-2016
1036	NICKEL	200.8	Y	MRL	5 UG/L		01-01-2014	12-31-2016
1045	SELENIUM	200.8	Y	MRL	5 UG/L		01-01-2014	12-31-2016
1052	SODIUM	200.7			0	5.5 MG/L	01-01-2014	12-31-2016
1055	SULFATE	300.0			0	24 MG/L	01-01-2014	12-31-2016
1074	ANTIMONY, TOTAL	200.8	Y	MRL	3 UG/L		01-01-2014	12-31-2016
1075	BERYLLIUM, TOTAL	200.8	Y	MRL	1 UG/L		01-01-2014	12-31-2016
1085	THALLIUM, TOTAL	200.8	Y	MRL	1 UG/L		01-01-2014	12-31-2016
1095	ZINC	200.8	Y	MRL	6 UG/L		01-01-2014	12-31-2016

Total Number of Records Fetched = 17

Drinking Water Branch

Chem/Rad Sample Results

[Return
Links](#)

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water
Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	8104678-01	Collection Date :	10-23-2018

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1005	ARSENIC	200.8	Y	MRL	1 UG/L		01-01-2017	12-31-2019
1010	BARIUM	200.8			0	110 UG/L	01-01-2017	12-31-2019
1015	CADMIUM	200.8	Y	MRL	1 UG/L		01-01-2017	12-31-2019
1017	CHLORIDE	300.0			0	2.9 MG/L	01-01-2017	12-31-2019
1020	CHROMIUM	200.8	Y	MRL	5 UG/L		01-01-2017	12-31-2019
1024	CYANIDE	335.4	Y	MRL	0.2 MG/L		01-01-2011	12-31-2019
1025	FLUORIDE	4500F-C			0	0.534 MG/L	01-01-2017	12-31-2019
1028	IRON	200.7			0	0.27 MG/L	01-01-2017	12-31-2019
1031	MAGNESIUM	200.7			0	36 MG/L		
1032	MANGANESE	200.8			0	4.9 UG/L	01-01-2017	12-31-2019
1035	MERCURY	200.8	Y	MRL	0.2 UG/L		01-01-2017	12-31-2019
1036	NICKEL	200.8	Y	MRL	5 UG/L		01-01-2017	12-31-2019
1045	SELENIUM	200.8	Y	MRL	2 UG/L		01-01-2017	12-31-2019
1052	SODIUM	200.7			0	4.2 MG/L	01-01-2017	12-31-2019
1055	SULFATE	300.0			0	20 MG/L	01-01-2017	12-31-2019
1074	ANTIMONY, TOTAL	200.8	Y	MRL	3 UG/L		01-01-2017	12-31-2019
1075	BERYLLIUM, TOTAL	200.8	Y	MRL	1 UG/L		01-01-2017	12-31-2019
1085	THALLIUM, TOTAL	200.8	Y	MRL	2 UG/L		01-01-2017	12-31-2019
1095	ZINC	200.8	Y	MRL	6 UG/L		01-01-2017	12-31-2019
1915	HARDNESS, TOTAL (AS CaCO3)	2340B			0	280 MG/L	01-01-2017	12-31-2019
1919	CALCIUM	200.7	N		0	53 MG/L	01-01-2017	12-31-2019
1927	ALKALINITY, TOTAL	2320B			0	270 MG/L	01-01-2017	12-31-2019
1930	TDS	2540C			0	270 MG/L	01-01-2017	12-31-2019

Total Number of Records Fetched = 23

Drinking Water Branch

Chem/Rad Sample Results

[Return
Links](#)

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water
Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	EL01848-02	Collection Date :	12-07-2021

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1005	ARSENIC	200.8	Y	MRL	1 UG/L			
1010	BARIUM	200.8			0	67 UG/L		
1015	CADMIUM	200.8	Y	MRL	1 UG/L			
1017	CHLORIDE	300.0	Y	MRL	1 MG/L			
1020	CHROMIUM	200.8	Y	MRL	4 UG/L			
1024	CYANIDE	335.4	Y	MRL	0.2 MG/L			
1025	FLUORIDE	4500F-C			0	0.635 MG/L		
1028	IRON	200.7			0	0.53 MG/L		
1031	MAGNESIUM	200.7			0	34 MG/L		
1032	MANGANESE	200.8			0	10 UG/L		
1035	MERCURY	200.8	Y	MRL	0.2 UG/L			
1036	NICKEL	200.8	Y	MRL	5 UG/L			
1045	SELENIUM	200.8	Y	MRL	1 UG/L			
1052	SODIUM	200.7			0	4 MG/L		
1055	SULFATE	300.0			0	11 MG/L		
1074	ANTIMONY, TOTAL	200.8	Y	MRL	3 UG/L			
1075	BERYLLIUM, TOTAL	200.8	Y	MRL	1 UG/L			
1085	THALLIUM, TOTAL	200.8	Y	MRL	1 UG/L			
1095	ZINC	200.8	Y	MRL	6 UG/L			
1915	HARDNESS, TOTAL (AS CaCO3)	2340B			0	300 MG/L		
1919	CALCIUM	200.7			0	63 MG/L		
1927	ALKALINITY, TOTAL	2320B			0	280 MG/L		
1930	TDS	2540C			0	280 MG/L		

Total Number of Records Fetched = 23

Drinking Water Branch

Chem/Rad Sample Results

[Return
Links](#)

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water
Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	5102164-02	Collection Date :	10-13-2015

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1005	ARSENIC	200.8	Y	MRL	1 UG/L		01-01-2014	12-31-2016
1010	BARIUM	200.8			0	62 UG/L	01-01-2014	12-31-2016
1015	CADMIUM	200.8	Y	MRL	1 UG/L		01-01-2014	12-31-2016
1020	CHROMIUM	200.8	Y	MRL	4 UG/L		01-01-2014	12-31-2016
1024	CYANIDE	4500CN-C	Y	MRL	0.2 MG/L		01-01-2011	12-31-2019
1025	FLUORIDE	4500F-C			0	1.01 MG/L	01-01-2014	12-31-2016
1028	IRON	200.7			0	0.54 MG/L	01-01-2014	12-31-2016
1032	MANGANESE	200.8			0	7.2 UG/L	01-01-2014	12-31-2016
1035	MERCURY	200.8	Y	MRL	0.2 UG/L		01-01-2014	12-31-2016
1036	NICKEL	200.8	Y	MRL	5 UG/L		01-01-2014	12-31-2016
1045	SELENIUM	200.8	Y	MRL	5 UG/L		01-01-2014	12-31-2016
1052	SODIUM	200.7			0	5.9 MG/L	01-01-2014	12-31-2016
1055	SULFATE	300.0			0	14 MG/L	01-01-2014	12-31-2016
1074	ANTIMONY, TOTAL	200.8	Y	MRL	3 UG/L		01-01-2014	12-31-2016
1075	BERYLLIUM, TOTAL	200.8	Y	MRL	1 UG/L		01-01-2014	12-31-2016
1085	THALLIUM, TOTAL	200.8	Y	MRL	1 UG/L		01-01-2014	12-31-2016
1095	ZINC	200.8	Y	MRL	6 UG/L		01-01-2014	12-31-2016

Total Number of Records Fetched = 17

Drinking Water Branch

Chem/Rad Sample Results

[Return
Links](#)

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water
Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	2103985-02	Collection Date :	10-29-2012

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1005	ARSENIC	200.8	Y	MRL	1 UG/L		01-01-2011	12-31-2013
1010	BARIUM	200.8			0	75 UG/L	01-01-2011	12-31-2013
1015	CADMIUM	200.8	Y	MRL	1 UG/L		01-01-2011	12-31-2013
1020	CHROMIUM	200.8	Y	MRL	4 UG/L		01-01-2011	12-31-2013
1024	CYANIDE	4500CN-C	Y	MRL	0.2 MG/L		01-01-2011	12-31-2019
1025	FLUORIDE	4500F-C			0	1.3 MG/L	01-01-2011	12-31-2013
1028	IRON	200.7			0	0.54 MG/L	01-01-2011	12-31-2013
1032	MANGANESE	200.8			0	10 UG/L	01-01-2011	12-31-2013
1035	MERCURY	200.8	Y	MRL	0.2 UG/L		01-01-2011	12-31-2013
1036	NICKEL	200.8			0	6.2 UG/L	01-01-2011	12-31-2013
1045	SELENIUM	200.8	Y	MRL	5 UG/L		01-01-2011	12-31-2013
1052	SODIUM	200.7			0	5.7 MG/L	01-01-2011	12-31-2013
1055	SULFATE	300.0			0	13 MG/L	01-01-2011	12-31-2013
1074	ANTIMONY, TOTAL	200.8	Y	MRL	3 UG/L		01-01-2011	12-31-2013
1075	BERYLLIUM, TOTAL	200.8	Y	MRL	1 UG/L		01-01-2011	12-31-2013
1085	THALLIUM, TOTAL	200.8	Y	MRL	2 UG/L		01-01-2011	12-31-2013
1095	ZINC	200.8	Y	MRL	6 UG/L		01-01-2011	12-31-2013

Total Number of Records Fetched = 17

Drinking Water Branch

Chem/Rad Sample Results

Return Links

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	0076499-02	Collection Date :	07-30-2020

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
4010	COMBINED RADIUM (-226 & -228)	null	null		null null	1.25 PCI/L	01-01-2020	12-31-2022
4020	RADIUM-226	903.1			0	0.58 PCI/L		
4030	RADIUM-228	904.0			0	0.669 PCI/L		
4109	GROSS ALPHA PARTICLE ACTIVITY	900.0	Y	MRL	2.72 PCI/L		01-01-2020	12-31-2025

Total Number of Records Fetched = 4

Drinking Water Branch

Chem/Rad Sample Results

Return Links

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	0076499-01	Collection Date :	07-30-2020

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
4010	COMBINED RADIUM (-226 & -228)	null	null		null null	1.05 PCI/L	01-01-2020	12-31-2022
4020	RADIUM-226	903.1			0	1.05 PCI/L		
4030	RADIUM-228	904.0	Y	MRL	0.621 PCI/L			
4109	GROSS ALPHA PARTICLE ACTIVITY	900.0			0	5.17 PCI/L	01-01-2020	12-31-2025

Total Number of Records Fetched = 4

Drinking Water Branch

Chem/Rad Sample Results

Return Links

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	4071413-01	Collection Date :	07-08-2014

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
4010	COMBINED RADIUM (-226 & -228)	null	null		null null	3.50 PCI/L	01-01-2014	12-31-2016
4020	RADIUM-226	903.1			0	1.62 PCI/L		
4030	RADIUM-228	904.0			0	1.88 PCI/L		
4109	GROSS ALPHA PARTICLE ACTIVITY	900			0	6.2 PCI/L	01-01-2014	12-31-2019

Total Number of Records Fetched = 4

Drinking Water Branch

Chem/Rad Sample Results

Return Links

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	5071155-01	Collection Date :	07-07-2015

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
4010	COMBINED RADIUM (-226 & -228)	null	null		null null	1.93 PCI/L	01-01-2014	12-31-2019
4020	RADIUM-226	903.1			0	1.07 PCI/L		
4030	RADIUM-228	904.0			0	0.864 PCI/L		
4109	GROSS ALPHA PARTICLE ACTIVITY	900			0	1.87 PCI/L	01-01-2014	12-31-2019

Total Number of Records Fetched = 4

Drinking Water Branch

Chem/Rad Sample Results

Return Links

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	GG04807-01	Collection Date :	07-25-2023

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
4010	COMBINED RADIUM (-226 & -228)	null	null		null null	4.38 PCI/L	01-01-2023	12-31-2025
4020	RADIUM-226	903.1			0	3.07 PCI/L		
4030	RADIUM-228	904.0			0	1.31 PCI/L		

Total Number of Records Fetched = 3

Drinking Water Branch

Chem/Rad Sample Results

Return Links

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	7072192-01	Collection Date :	07-11-2017

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
4010	COMBINED RADIUM (-226 & -228)	null	null		null null	1.62 PCI/L	01-01-2017	12-31-2019
4020	RADIUM-226	903.1			0	0.96 PCI/L		
4030	RADIUM-228	904.0			0	0.663 PCI/L		

Total Number of Records Fetched = 3

Drinking Water Branch

Chem/Rad Sample Results

[Return
Links](#)

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water
Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	2103985-01	Collection Date :	10-29-2012

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1005	ARSENIC	200.8	Y	MRL	1 UG/L		01-01-2011	12-31-2013
1010	BARIUM	200.8			0	110 UG/L	01-01-2011	12-31-2013
1015	CADMIUM	200.8	Y	MRL	1 UG/L		01-01-2011	12-31-2013
1020	CHROMIUM	200.8	Y	MRL	4 UG/L		01-01-2011	12-31-2013
1024	CYANIDE	4500CN-C	Y	MRL	0.2 MG/L		01-01-2011	12-31-2019
1025	FLUORIDE	4500F-C			0	0.702 MG/L	01-01-2011	12-31-2013
1028	IRON	200.7			0	0.45 MG/L	01-01-2011	12-31-2013
1032	MANGANESE	200.8			0	8 UG/L	01-01-2011	12-31-2013
1035	MERCURY	200.8	Y	MRL	0.2 UG/L		01-01-2011	12-31-2013
1036	NICKEL	200.8	Y	MRL	5 UG/L		01-01-2011	12-31-2013
1045	SELENIUM	200.8	Y	MRL	5 UG/L		01-01-2011	12-31-2013
1052	SODIUM	200.7			0	2.4 MG/L	01-01-2011	12-31-2013
1055	SULFATE	300.0			0	21 MG/L	01-01-2011	12-31-2013
1074	ANTIMONY, TOTAL	200.8	Y	MRL	3 UG/L		01-01-2011	12-31-2013
1075	BERYLLIUM, TOTAL	200.8	Y	MRL	1 UG/L		01-01-2011	12-31-2013
1085	THALLIUM, TOTAL	200.8	Y	MRL	2 UG/L		01-01-2011	12-31-2013
1095	ZINC	200.8			0	12 UG/L	01-01-2011	12-31-2013

Total Number of Records Fetched = 17

Drinking Water Branch

Chem/Rad Sample Results

[Return Links](#)

[Chem/Rad Samples](#)

[Analyte List](#)

[Water System Detail](#)

[Water Systems](#)

[Water System Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	0033063-01	Collection Date :	03-16-2020

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1024	CYANIDE	335.4	Y	MRL	0.2 MG/L		01-01-2020	12-31-2028
2005	ENDRIN	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2010	BHC-GAMMA	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2015	METHOXYCHLOR	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2020	TOXAPHENE	525.2	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2031	DALAPON	515.3	Y	MRL	5 UG/L		01-01-2020	12-31-2028
2032	DIQUAT	549.2	Y	MRL	2 UG/L		01-01-2020	12-31-2028
2033	ENDOTHALL	548.1	Y	MRL	9 UG/L		01-01-2020	12-31-2028
2035	DI(2-ETHYLHEXYL) ADIPATE	525.2	Y	MRL	0.6 UG/L		01-01-2020	12-31-2028
2037	SIMAZINE	525.2	Y	MRL	0.35 UG/L		01-01-2020	12-31-2028
2039	DI(2-ETHYLHEXYL) PHTHALATE	525.2	Y	MRL	1.8 UG/L		01-01-2020	12-31-2028
2040	PICLORAM	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2041	DINOSEB	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2042	HEXACHLOROCYCLOPENTADIENE	525.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2028
2050	ATRAZINE	525.2	Y	MRL	0.3 UG/L		01-01-2020	12-31-2028
2051	LASSO	525.2	Y	MRL	0.2 UG/L		01-01-2020	12-31-2028
2065	HEPTACHLOR	525.2	Y	MRL	0.04 UG/L		01-01-2020	12-31-2028
2067	HEPTACHLOR EPOXIDE	525.2	Y	MRL	0.02 UG/L		01-01-2020	12-31-2028
2070	DIELDRIN	525.2	Y	MRL	0.25 UG/L		01-01-2020	12-31-2028
2077	PROPACHLOR	525.2	Y	MRL	0.5 UG/L			
2105	2,4-D	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2110	2,4,5-TP	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2251	METHYL TERT-BUTYL ETHER	524.2	Y	MRL	0.5 UG/L			
2274	HEXACHLOROBENZENE	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2306	BENZO(A)PYRENE	550	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2326	PENTACHLOROPHENOL	515.3	Y	MRL	0.4 UG/L		01-01-2020	12-31-2028
2356	ALDRIN	525.2	Y	MRL	0.25 UG/L		01-01-2020	12-31-2028
2378	1,2,4-TRICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2380	CIS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2440	DICAMBA	515.3	Y	MRL	0.3 UG/L			
2775	TOTAL DDT	525.2	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2931	1,2-DIBROMO-3-CHLOROPROPANE	504.1	Y	MRL	0.02 UG/L		01-01-2020	12-31-2028
2946	ETHYLENE DIBROMIDE	504.1	Y	MRL	0.01 UG/L		01-01-2020	12-31-2028
2955	XYLENES, TOTAL	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2959	CHLORDANE	525.2	Y	MRL	0.2 UG/L		01-01-2020	12-31-2028
2964	DICHLOROMETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2968	O-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2969	P-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2976	VINYL CHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2977	1,1-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2979	TRANS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025

2980	1,2-DICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2981	1,1,1-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2982	CARBON TETRACHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2983	1,2-DICHLOROPROPANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2984	TRICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2985	1,1,2-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2987	TETRACHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2989	CHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2990	BENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2991	TOLUENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2992	ETHYLBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2996	STYRENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025

Total Number of Records Fetched = 54

Drinking Water Branch

Chem/Rad Sample Results

[Return Links](#)

[Chem/Rad Samples](#)

[Analyte List](#)

[Water System Detail](#)

[Water Systems](#)

[Water System Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	4012618-02	Collection Date :	01-21-2014

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
2251	METHYL TERT-BUTYL ETHER	524.2	Y	MRL	0.5 UG/L			
2378	1,2,4-TRICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2380	CIS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2955	XYLENES, TOTAL	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2964	DICHLROMETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2968	O-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2969	P-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2976	VINYL CHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2977	1,1-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2979	TRANS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2980	1,2-DICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2981	1,1,1-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2982	CARBON TETRACHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2983	1,2-DICHLOROPROPANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2984	TRICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2985	1,1,2-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2987	TETRACHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2989	CHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2990	BENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2991	TOLUENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2992	ETHYLBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2996	STYRENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019

Total Number of Records Fetched = 22

Drinking Water Branch

Chem/Rad Sample Results

[Return Links](#)

[Chem/Rad Samples](#)

[Analyte List](#)

[Water System Detail](#)

[Water Systems](#)

[Water System Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	0023214-01	Collection Date :	02-18-2020

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1024	CYANIDE	335.4	Y	MRL	0.2 MG/L		01-01-2020	12-31-2028
2005	ENDRIN	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2010	BHC-GAMMA	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2015	METHOXYCHLOR	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2020	TOXAPHENE	525.2	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2021	CARBARYL	531.1	Y	MRL	2 UG/L			
2022	METHOMYL	531.1	Y	MRL	0.5 UG/L			
2031	DALAPON	515.3	Y	MRL	5 UG/L		01-01-2020	12-31-2028
2032	DIQUAT	549.2	Y	MRL	2 UG/L		01-01-2020	12-31-2028
2033	ENDOTHALL	548.1	Y	MRL	9 UG/L		01-01-2020	12-31-2028
2035	DI(2-ETHYLHEXYL) ADIPATE	525.2	Y	MRL	0.6 UG/L		01-01-2020	12-31-2028
2036	OXAMYL	531.1	Y	MRL	2 UG/L		01-01-2020	12-31-2028
2037	SIMAZINE	525.2	Y	MRL	0.35 UG/L		01-01-2020	12-31-2028
2039	DI(2-ETHYLHEXYL) PHTHALATE	525.2	Y	MRL	1.8 UG/L		01-01-2020	12-31-2028
2040	PICLORAM	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2041	DINOSEB	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2042	HEXACHLOROCYCLOPENTADIENE	525.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2028
2046	CARBOFURAN	531.1	Y	MRL	0.9 UG/L		01-01-2020	12-31-2028
2050	ATRAZINE	525.2	Y	MRL	0.3 UG/L		01-01-2020	12-31-2028
2051	LASSO	525.2	Y	MRL	0.2 UG/L		01-01-2020	12-31-2028
2065	HEPTACHLOR	525.2	Y	MRL	0.04 UG/L		01-01-2020	12-31-2028
2066	3-HYDROXYCARBOFURAN	531.1	Y	MRL	1 UG/L			
2067	HEPTACHLOR EPOXIDE	525.2	Y	MRL	0.02 UG/L		01-01-2020	12-31-2028
2070	DIELDRIN	525.2	Y	MRL	0.25 UG/L		01-01-2020	12-31-2028
2077	PROPACHLOR	525.2	Y	MRL	0.5 UG/L			
2105	2,4-D	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2110	2,4,5-TP	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2251	METHYL TERT-BUTYL ETHER	524.2	Y	MRL	0.5 UG/L			
2274	HEXACHLOROBENZENE	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2306	BENZO(A)PYRENE	550	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2326	PENTACHLOROPHENOL	515.3	Y	MRL	0.4 UG/L		01-01-2020	12-31-2028
2356	ALDRIN	525.2	Y	MRL	0.25 UG/L		01-01-2020	12-31-2028
2378	1,2,4-TRICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2380	CIS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2440	DICAMBA	515.3	Y	MRL	0.3 UG/L			
2775	TOTAL DDT	525.2	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2931	1,2-DIBROMO-3-CHLOROPROPANE	504.1	Y	MRL	0.02 UG/L		01-01-2020	12-31-2028
2946	ETHYLENE DIBROMIDE	504.1	Y	MRL	0.01 UG/L		01-01-2020	12-31-2028
2955	XYLENES, TOTAL	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2959	CHLORDANE	525.2	Y	MRL	0.2 UG/L		01-01-2020	12-31-2028
2964	DICHLOROMETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025

2968	O-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2969	P-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2976	VINYL CHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2977	1,1-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2979	TRANS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2980	1,2-DICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2981	1,1,1-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2982	CARBON TETRACHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2983	1,2-DICHLOROPROPANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2984	TRICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2985	1,1,2-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2987	TETRACHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2989	CHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2990	BENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2991	TOLUENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2992	ETHYLBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2996	STYRENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025

Total Number of Records Fetched = 59

Drinking Water Branch

Chem/Rad Sample Results

[Return Links](#)

[Chem/Rad Samples](#)

[Analyte List](#)

[Water System Detail](#)

[Water Systems](#)

[Water System Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	4021074-01	Collection Date :	02-10-2014

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
2251	METHYL TERT-BUTYL ETHER	524.2	Y	MRL	0.5 UG/L			
2378	1,2,4-TRICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2380	CIS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2955	XYLENES, TOTAL	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2964	DICHLROMETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2968	O-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2969	P-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2976	VINYL CHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2977	1,1-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2979	TRANS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2980	1,2-DICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2981	1,1,1-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2982	CARBON TETRACHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2983	1,2-DICHLOROPROPANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2984	TRICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2985	1,1,2-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2987	TETRACHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2989	CHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2990	BENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2991	TOLUENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2992	ETHYLBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019
2996	STYRENE	524.2	Y	MRL	0.5 UG/L		01-01-2014	12-31-2019

Total Number of Records Fetched = 22

Drinking Water Branch

Chem/Rad Sample Results

Return Links

[Chem/Rad
Samples](#)

[Analyte List](#)

[Water System
Detail](#)

[Water Systems](#)

[Water System
Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	0076499-02	Collection Date :	07-30-2020

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
4010	COMBINED RADIUM (-226 & -228)	null	null		null null	1.25 PCI/L	01-01-2020	12-31-2022
4020	RADIUM-226	903.1			0	0.58 PCI/L		
4030	RADIUM-228	904.0			0	0.669 PCI/L		
4109	GROSS ALPHA PARTICLE ACTIVITY	900.0	Y	MRL	2.72 PCI/L		01-01-2020	12-31-2025

Total Number of Records Fetched = 4

Drinking Water Branch

Chem/Rad Sample Results

[Return Links](#)

[Chem/Rad Samples](#)

[Analyte List](#)

[Water System Detail](#)

[Water Systems](#)

[Water System Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	11021045-1	Collection Date :	01-31-2011

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1024	CYANIDE	335.4	Y	MRL	0.01 MG/L		01-01-2011	12-31-2019
2005	ENDRIN	508	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2010	BHC-GAMMA	508	Y	MRL	0.01 UG/L		01-01-2011	12-31-2019
2015	METHOXYCHLOR	508	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2020	TOXAPHENE	508	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2031	DALAPON	515.3	Y	MRL	5 UG/L		01-01-2011	12-31-2019
2032	DIQUAT	549.2	Y	MRL	2 UG/L		01-01-2011	12-31-2019
2033	ENDOTHALL	548.1	Y	MRL	9 UG/L		01-01-2011	12-31-2019
2035	DI(2-ETHYLHEXYL) ADIPATE	525.2	Y	MRL	40 UG/L		01-01-2011	12-31-2019
2036	OXAMYL	531.1	Y	MRL	2 UG/L		01-01-2011	12-31-2019
2037	SIMAZINE	525.2	Y	MRL	0.4 UG/L		01-01-2011	12-31-2019
2039	DI(2-ETHYLHEXYL) PHTHALATE	525.2	Y	MRL	1.8 UG/L		01-01-2011	12-31-2019
2040	PICLORAM	515.3	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2041	DINOSEB	515.3	Y	MRL	0.7 UG/L		01-01-2011	12-31-2019
2042	HEXACHLOROCYCLOPENTADIENE	508	Y	MRL	0.5 UG/L		01-01-2011	12-31-2019
2043	ALDICARB SULFOXIDE	531.1	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2044	ALDICARB SULFONE	531.1	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2046	CARBOFURAN	531.1	Y	MRL	0.9 UG/L		01-01-2011	12-31-2019
2047	ALDICARB	531.1	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2050	ATRAZINE	525.2	Y	MRL	0.3 UG/L		01-01-2011	12-31-2019
2051	LASSO	525.2	Y	MRL	0.2 UG/L		01-01-2011	12-31-2019
2065	HEPTACHLOR	508	Y	MRL	0.04 UG/L		01-01-2011	12-31-2019
2067	HEPTACHLOR EPOXIDE	508	Y	MRL	0.02 UG/L		01-01-2011	12-31-2019
2070	DIELDRIN	508	Y	MRL	0.05 UG/L		01-01-2011	12-31-2019
2105	2,4-D	515.3	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2110	2,4,5-TP	515.3	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2274	HEXACHLOROBENZENE	508	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2306	BENZO(A)PYRENE	525.2	Y	MRL	0.02 UG/L		01-01-2011	12-31-2019
2326	PENTACHLOROPHENOL	515.3	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2356	ALDRIN	508	Y	MRL	0.05 UG/L		01-01-2011	12-31-2019
2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	508	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2775	TOTAL DDT	508	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2931	1,2-DIBROMO-3-CHLOROPROPANE	504.1	Y	MRL	0.02 UG/L		01-01-2011	12-31-2019
2946	ETHYLENE DIBROMIDE	504.1	Y	MRL	0.01 UG/L		01-01-2011	12-31-2019
2959	CHLORDANE	508	Y	MRL	0.2 UG/L		01-01-2011	12-31-2019

Total Number of Records Fetched = 35

Drinking Water Branch

Chem/Rad Sample Results

[Return Links](#)

[Chem/Rad Samples](#)

[Analyte List](#)

[Water System Detail](#)

[Water Systems](#)

[Water System Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	0023214-01	Collection Date :	02-18-2020

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1024	CYANIDE	335.4	Y	MRL	0.2 MG/L		01-01-2020	12-31-2028
2005	ENDRIN	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2010	BHC-GAMMA	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2015	METHOXYCHLOR	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2020	TOXAPHENE	525.2	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2021	CARBARYL	531.1	Y	MRL	2 UG/L			
2022	METHOMYL	531.1	Y	MRL	0.5 UG/L			
2031	DALAPON	515.3	Y	MRL	5 UG/L		01-01-2020	12-31-2028
2032	DIQUAT	549.2	Y	MRL	2 UG/L		01-01-2020	12-31-2028
2033	ENDOTHALL	548.1	Y	MRL	9 UG/L		01-01-2020	12-31-2028
2035	DI(2-ETHYLHEXYL) ADIPATE	525.2	Y	MRL	0.6 UG/L		01-01-2020	12-31-2028
2036	OXAMYL	531.1	Y	MRL	2 UG/L		01-01-2020	12-31-2028
2037	SIMAZINE	525.2	Y	MRL	0.35 UG/L		01-01-2020	12-31-2028
2039	DI(2-ETHYLHEXYL) PHTHALATE	525.2	Y	MRL	1.8 UG/L		01-01-2020	12-31-2028
2040	PICLORAM	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2041	DINOSEB	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2042	HEXACHLOROCYCLOPENTADIENE	525.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2028
2046	CARBOFURAN	531.1	Y	MRL	0.9 UG/L		01-01-2020	12-31-2028
2050	ATRAZINE	525.2	Y	MRL	0.3 UG/L		01-01-2020	12-31-2028
2051	LASSO	525.2	Y	MRL	0.2 UG/L		01-01-2020	12-31-2028
2065	HEPTACHLOR	525.2	Y	MRL	0.04 UG/L		01-01-2020	12-31-2028
2066	3-HYDROXYCARBOFURAN	531.1	Y	MRL	1 UG/L			
2067	HEPTACHLOR EPOXIDE	525.2	Y	MRL	0.02 UG/L		01-01-2020	12-31-2028
2070	DIELDIN	525.2	Y	MRL	0.25 UG/L		01-01-2020	12-31-2028
2077	PROPACHLOR	525.2	Y	MRL	0.5 UG/L			
2105	2,4-D	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2110	2,4,5-TP	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2251	METHYL TERT-BUTYL ETHER	524.2	Y	MRL	0.5 UG/L			
2274	HEXACHLOROBENZENE	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2306	BENZO(A)PYRENE	550	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2326	PENTACHLOROPHENOL	515.3	Y	MRL	0.4 UG/L		01-01-2020	12-31-2028
2356	ALDRIN	525.2	Y	MRL	0.25 UG/L		01-01-2020	12-31-2028
2378	1,2,4-TRICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2380	CIS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2440	DICAMBA	515.3	Y	MRL	0.3 UG/L			
2775	TOTAL DDT	525.2	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2931	1,2-DIBROMO-3-CHLOROPROPANE	504.1	Y	MRL	0.02 UG/L		01-01-2020	12-31-2028
2946	ETHYLENE DIBROMIDE	504.1	Y	MRL	0.01 UG/L		01-01-2020	12-31-2028
2955	XYLENES, TOTAL	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2959	CHLORDANE	525.2	Y	MRL	0.2 UG/L		01-01-2020	12-31-2028
2964	DICHLOROMETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025

2968	O-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2969	P-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2976	VINYL CHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2977	1,1-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2979	TRANS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2980	1,2-DICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2981	1,1,1-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2982	CARBON TETRACHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2983	1,2-DICHLOROPROPANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2984	TRICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2985	1,1,2-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2987	TETRACHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2989	CHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2990	BENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2991	TOLUENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2992	ETHYLBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2996	STYRENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025

Total Number of Records Fetched = 59

Drinking Water Branch

Chem/Rad Sample Results

[Return Links](#)

[Chem/Rad Samples](#)

[Analyte List](#)

[Water System Detail](#)

[Water Systems](#)

[Water System Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	0033063-01	Collection Date :	03-16-2020

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1024	CYANIDE	335.4	Y	MRL	0.2 MG/L		01-01-2020	12-31-2028
2005	ENDRIN	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2010	BHC-GAMMA	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2015	METHOXYCHLOR	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2020	TOXAPHENE	525.2	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2031	DALAPON	515.3	Y	MRL	5 UG/L		01-01-2020	12-31-2028
2032	DIQUAT	549.2	Y	MRL	2 UG/L		01-01-2020	12-31-2028
2033	ENDOTHALL	548.1	Y	MRL	9 UG/L		01-01-2020	12-31-2028
2035	DI(2-ETHYLHEXYL) ADIPATE	525.2	Y	MRL	0.6 UG/L		01-01-2020	12-31-2028
2037	SIMAZINE	525.2	Y	MRL	0.35 UG/L		01-01-2020	12-31-2028
2039	DI(2-ETHYLHEXYL) PHTHALATE	525.2	Y	MRL	1.8 UG/L		01-01-2020	12-31-2028
2040	PICLORAM	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2041	DINOSEB	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2042	HEXACHLOROCYCLOPENTADIENE	525.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2028
2050	ATRAZINE	525.2	Y	MRL	0.3 UG/L		01-01-2020	12-31-2028
2051	LASSO	525.2	Y	MRL	0.2 UG/L		01-01-2020	12-31-2028
2065	HEPTACHLOR	525.2	Y	MRL	0.04 UG/L		01-01-2020	12-31-2028
2067	HEPTACHLOR EPOXIDE	525.2	Y	MRL	0.02 UG/L		01-01-2020	12-31-2028
2070	DIELDRIN	525.2	Y	MRL	0.25 UG/L		01-01-2020	12-31-2028
2077	PROPACHLOR	525.2	Y	MRL	0.5 UG/L			
2105	2,4-D	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2110	2,4,5-TP	515.3	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2251	METHYL TERT-BUTYL ETHER	524.2	Y	MRL	0.5 UG/L			
2274	HEXACHLOROBENZENE	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2306	BENZO(A)PYRENE	550	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2326	PENTACHLOROPHENOL	515.3	Y	MRL	0.4 UG/L		01-01-2020	12-31-2028
2356	ALDRIN	525.2	Y	MRL	0.25 UG/L		01-01-2020	12-31-2028
2378	1,2,4-TRICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2380	CIS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	525.2	Y	MRL	0.1 UG/L		01-01-2020	12-31-2028
2440	DICAMBA	515.3	Y	MRL	0.3 UG/L			
2775	TOTAL DDT	525.2	Y	MRL	1 UG/L		01-01-2020	12-31-2028
2931	1,2-DIBROMO-3-CHLOROPROPANE	504.1	Y	MRL	0.02 UG/L		01-01-2020	12-31-2028
2946	ETHYLENE DIBROMIDE	504.1	Y	MRL	0.01 UG/L		01-01-2020	12-31-2028
2955	XYLENES, TOTAL	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2959	CHLORDANE	525.2	Y	MRL	0.2 UG/L		01-01-2020	12-31-2028
2964	DICHLOROMETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2968	O-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2969	P-DICHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2976	VINYL CHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2977	1,1-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2979	TRANS-1,2-DICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025

2980	1,2-DICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2981	1,1,1-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2982	CARBON TETRACHLORIDE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2983	1,2-DICHLOROPROPANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2984	TRICHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2985	1,1,2-TRICHLOROETHANE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2987	TETRACHLOROETHYLENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2989	CHLOROBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2990	BENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2991	TOLUENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2992	ETHYLBENZENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025
2996	STYRENE	524.2	Y	MRL	0.5 UG/L		01-01-2020	12-31-2025

Total Number of Records Fetched = 54

Drinking Water Branch

Chem/Rad Sample Results

[Return Links](#)

[Chem/Rad Samples](#)

[Analyte List](#)

[Water System Detail](#)

[Water Systems](#)

[Water System Search](#)

[County Map](#)

[Glossary](#)

Water System No. :	IL0855150	Federal Type :	C
Water System Name :	PRAIRIE PATH WATER COMPANY-APPLE CANYON	State Type :	C
Principal County Served :	JO DAVIESS	Primary Source :	GW
Status :	A	Activity Date :	01-01-1970
Lab Sample No. :	11021494-1	Collection Date :	02-07-2011

This list displays sample/results of all non-microbial analytes (TSAANLYT.TYPE_CODE <> MOR) associated to the selected sample. Results for Microbial Analytes are not included.

Analyte Code	Analyte Name	Method Code	Less than Indicator	Level Type	Reporting Level	Concentration level	Monitoring Period Begin Date	Monitoring Period End Date
1024	CYANIDE	335.4	Y	MRL	0.01 MG/L		01-01-2011	12-31-2019
2005	ENDRIN	508	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2010	BHC-GAMMA	508	Y	MRL	0.01 UG/L		01-01-2011	12-31-2019
2015	METHOXYCHLOR	508	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2020	TOXAPHENE	508	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2031	DALAPON	515.3	Y	MRL	5 UG/L		01-01-2011	12-31-2019
2032	DIQUAT	549.2	Y	MRL	2 UG/L		01-01-2011	12-31-2019
2033	ENDOTHALL	548.1	Y	MRL	9 UG/L		01-01-2011	12-31-2019
2035	DI(2-ETHYLHEXYL) ADIPATE	525.2	Y	MRL	40 UG/L		01-01-2011	12-31-2019
2036	OXAMYL	531.1	Y	MRL	2 UG/L		01-01-2011	12-31-2019
2037	SIMAZINE	525.2	Y	MRL	0.4 UG/L		01-01-2011	12-31-2019
2039	DI(2-ETHYLHEXYL) PHTHALATE	525.2	Y	MRL	1.8 UG/L		01-01-2011	12-31-2019
2040	PICLORAM	515.3	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2041	DINOSEB	515.3	Y	MRL	0.7 UG/L		01-01-2011	12-31-2019
2042	HEXACHLOROCYCLOPENTADIENE	508	Y	MRL	0.5 UG/L		01-01-2011	12-31-2019
2043	ALDICARB SULFOXIDE	531.1	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2044	ALDICARB SULFONE	531.1	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2046	CARBOFURAN	531.1	Y	MRL	0.9 UG/L		01-01-2011	12-31-2019
2047	ALDICARB	531.1	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2050	ATRAZINE	525.2	Y	MRL	0.3 UG/L		01-01-2011	12-31-2019
2051	LASSO	525.2	Y	MRL	0.2 UG/L		01-01-2011	12-31-2019
2065	HEPTACHLOR	508	Y	MRL	0.04 UG/L		01-01-2011	12-31-2019
2067	HEPTACHLOR EPOXIDE	508	Y	MRL	0.02 UG/L		01-01-2011	12-31-2019
2070	DIELDRIN	508	Y	MRL	0.05 UG/L		01-01-2011	12-31-2019
2105	2,4-D	515.3	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2110	2,4,5-TP	515.3	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2274	HEXACHLOROBENZENE	508	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2306	BENZO(A)PYRENE	525.2	Y	MRL	0.02 UG/L		01-01-2011	12-31-2019
2326	PENTACHLOROPHENOL	515.3	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2356	ALDRIN	508	Y	MRL	0.05 UG/L		01-01-2011	12-31-2019
2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	508	Y	MRL	0.1 UG/L		01-01-2011	12-31-2019
2775	TOTAL DDT	508	Y	MRL	1 UG/L		01-01-2011	12-31-2019
2931	1,2-DIBROMO-3-CHLOROPROPANE	504.1	Y	MRL	0.02 UG/L		01-01-2011	12-31-2019
2946	ETHYLENE DIBROMIDE	504.1	Y	MRL	0.01 UG/L		01-01-2011	12-31-2019
2959	CHLORDANE	508	Y	MRL	0.2 UG/L		01-01-2011	12-31-2019

Total Number of Records Fetched = 35