

Green Ridge Water System

All results reported as Nanograms per liter(ng/L)						
Sampling Location	Date Sampled	PFOS	PFOA	Combined PFOS + PFOA	EPA Health Advisory Level	Result Below Health Advisory Level?
Entry Point Station 1	3/31/2020	2.3	6.6	8.9	70	Yes
Entry Point Station 2	3/31/2020	2.6	3.8	6.4	70	Yes
Entry Point Station 3	3/31/2020	2.1	3.3	5.4	70	Yes
Bulk Provider Meter	2/16/2021	ND	ND	ND	70	Yes
Resample Results:						
Entry Point Station 1	2/16/2021	3.3	4.6	7.9	70	Yes
Entry Point Station 2	2/16/2021	2.7	8.5	11.2	70	Yes
Entry Point Station 3	2/16/2021	3.3	4.6	7.9	70	Yes

- **PFOS** – Perfluorooctane Sulfonate
- **PFOA** – Perfluorooctanoic Acid
- **Health Advisory Level (HAL)** – To provide Americans, including the most sensitive populations, with a margin of protection from a lifetime of exposure to PFOA and PFOS from drinking water, EPA established the health advisory levels at 70 parts per trillion.
- **Ng/L** – Nanograms per liter(ng/L) which equals Parts per trillion (ppt) – One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
- **ND (No Detect)** - Laboratory analysis indicates that the constituent is not present. 2.0 ng/L is the minimum level the lab is reporting a detection for these parameters. The ND (No Detect) represented in the table is indicating there was no detection.